

Model 431

File Number: R7311

COMPANY

3M Company
3M CENTER
SAINT PAUL, MN 55144-1000 United States

MODEL INFO

431

SURFACE BURNING CHARACTERISTICS - U.S.

Substrate Applied To	Quantity of Longitudinal Strips Tested	Spacing of Strips On Center for Test, inch	Tested Tape Width, inch	Percentage of Exposed Test Area, %	Flame Spread Index	Smoke Developed Index
Inorganic Reinforced Cement Board	--	--	--	67	10	0



The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."